

**ITEM 05203.09 M - SELECT GRANULAR FILL (PVC WATER LINE)**

The requirements of Section 203 - Excavation And Embankment pertaining to Select granular Fill shall apply except as modified herein.

**MATERIALS:**

The use of crushed granular material shall not be allowed.

The maximum particle size of the gradation requirements shall be 100 percent by weight passing the 25 mm sieve.

**CONSTRUCTION DETAILS:**

After placing the select fill over the top of the pipe to the depth specified on the plans, the material shall be compacted by two passes of a pan type vibrator or small vibratory roller approved by the Engineer

This  
Specification  
has been  
Disapproved  
as a result  
of the issuance  
of  
EI 00-038