

**ITEM 16556.01 M - REINFORCING STEEL FOR CONCRETE STRUCTURES-
GALVANIZED**

The requirements of §556 - Reinforcing Steel for Concrete Structures shall apply with the following modifications:

1. All reinforcing shall be cut and bent prior to galvanizing.
2. All reinforcing shall meet the requirements of §709-11 Galvanized Bar Reinforcement, Grade 400.
3. Tie wire shall be 16 gauge or larger and shall be galvanized or coated with a non-conducting material.
4. The Contractor shall follow ASTM A767 - 95 Zinc-Coated (Galvanized) Steel Bars for Concrete Reinforcement, Appendix X1. Guidelines for Job-Site Practices subsections X1.3.1 - X1.3.12 during construction operations.