

ITEM 10607.3001 M - STEEL CHAIN LINK FENCE WITH TOP RAIL, 1220 mm HIGH
ITEM 10607.3002 M - STEEL CHAIN LINK FENCE WITH TOP RAIL, 1830 mm HIGH
ITEM 10607.3003 M - STEEL CHAIN LINK FENCE WITH TOP RAIL, 2440 mm HIGH
ITEM 10607.3004 M - STEEL CHAIN LINK FENCE WITH TOP RAIL, 3050 mm HIGH
ITEM 10607.3005 M - STEEL CHAIN LINK FENCE WITH TOP RAIL, 3660 mm HIGH

All the provisions of Section 607 pertaining to Optional Chain Link Fence, Type I, with Top Rail shall apply except for the following:

The fence fabric and frame options shall be listed below:

	<u>Fabric</u>	<u>Frame</u>
1.	Galvanized Steel	Galvanized Steel
2.	Aluminum Coated Steel	Aluminum Coated Steel or Combined Coating on Steel

End, corner, pull and line posts, top rail and braces shall be either Class A, Schedule 40 Pipe or Class B, Steel Tubing, at the Contractor's option. The alternative Roll-formed and H Section posts, top rail and braces shall not be used. The size of the posts, top rail and braces shall be as indicated on the Standard Sheets.

Fittings shall conform to the requirements of Subsection 710-10 except that aluminum alloy fittings shall not be used.

Gate posts shall be steel of the type and size indicated on Standard Sheets except that the optional Roll-formed posts shall not be used.

The fence fabric shall be attached to the line posts with matching tie wires; either galvanized steel or aluminum coated steel. The tie wires shall be 9 gage (3.759 mm Nominal Coated Wire Diameter) and shall be spaced at a maximum of 350 mm. The tie wires shall be installed in accordance with the special note "Fence Fabric Tie Wires" which is included elsewhere in the proposal. Minor damage to the coating on the tie wires, caused by cutting and twisting operations, will be acceptable as determined by the Engineer.

The fabric shall be secured to all end, corner, pull and gate posts with stretcher bars fastened to the posts with stretcher bands spaced at a maximum of 350 mm. When the installation of the fencing is completed, the threads of the bolts in the stretcher bands shall be damaged, as directed by the Engineer, to prevent removal of bolts.